



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 240127260-LAA

Issued: 12/18/2015  
3:02 PM

Expires: 12/18/2016

Address: BRONX 582 SOUTHERN BLVD

Issued to: THOMAS CATALANO

Floors: BAS 001 thru 005

Business: CATALANO PLBG & HTG INC

Licensee No: P - 001795

Description of Work: *Plumbing: GAS PLUMBING WORK*

*Gas Usage(s): Cooking*

*TO INSTALL FOUR (4) 2" LOCK WING GAS COCKS TO ISOLATE RISERS ON METER BANK LOCATED IN BASEMENT FOR FUTURE GAS REPAIRS AS PER CON ED REQUEST-WILL USE APPRX 10' OF 2" BLK PIPE & FOUR 2" LOCK WING GAS VALVES-WILL TEST ALL 35 APTS- NO GAS IN PUBLIC HALLWAYS-FIRESTOPS AS PER NYC CODE-APPLIANCES ON EXISTING 35 METERS ARE STOVES. ADDITIONAL LAA TO FOLLOW IF NECESSARY. A414/6GM/A0426/6GM\_0519/6GM*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 02/23/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.