



Buildings



LAA Permit Department of Buildings

Permit Number: **240164905-LAA**

Issued: **11/29/2016
2:27 PM**

Expires: **11/29/2017**

Address: **BRONX 200 BAYCHESTER AVENUE**

Issued to: **JOHN C BOWER**

Business: **ABCO PEERLESS SPRNK CORP**

Floors: **001**

Licensee No: **F - 000177**

Description of Work: **Fire Suppression: FIRE SUPPRESSION WORK**

INSTALLATION OF (4) NEW SPRINKLER HEADS USING APPROXIMATELY 36'-0" OF 1" PIPING AND REARRANGE (19) SPRINKLER HEADS USING APPROXIMATELY 133'-0" OF 1" PIPING IN THE JOURNEYS KIDZ SPACE. SYSTEM TO BE DOWN LESS THEN 4 HOURS. THIS IS LOCATED IN A STRIP MALL. NO CHANGE TO USE, OCCUPANCY OR EGRESS.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 09/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.