




Buildings



LAA Permit Department of Buildings

Permit Number: 240184484-LAA

Issued: 05/24/2017
2:10 PM

Expires: 05/24/2018

Address: BRONX 925 HUNTS POINT AVENUE

Issued to: ADAM M LEVINE

Business: CAPITOL FIRE SPRINKLER CO

Floors: 001

Licensee No: F - 001063

Description of Work: Fire Suppression: FIRE SUPPRESSION WORK

ADDING 5 NEW UPRIGHT HEADS WITH APPROXIMATELY 20' OF 1-1/4" PIPE AND 30' OF 1" PIPE & REARRANGE 9 EXISTING UPRIGHT HEADS WITH APPROXIMATELY 30' OF 1" PIPE DUE TO THE INSTALLATION OF A NEW WALL. THE SYSTEM WILL BE DOWN FOR LESS THAN 6 HOURS. FIRE STOPPING WILL NOT BE COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/17/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.