



Buildings

Issued:

LAA Permit Department of Buildings

Permit Number: 240196747-LAA

08/30/2017 1:03 PM

Expires: 08/30/2018

James S. Odds

Issued to: CHRISTOPHER C HAY

Address: BRONX 1275 WEBSTER AVE

Business: HAY MECHANICAL SOLUTIONS

Floors: CEL Licensee No: P - 001952

Description of Work: Plumbing: WATER PLUMBING WORK

INSTALL 1 NEW PRIMARY RPZ VALVE AT CELLAR WATER MAIN LOCATION.DEP APPROVAL NUMBER 15059383, MODEL 11/2 WATTS LF009M2QT VALVE, MEA# 140-04-M, ANSI 61 THIS INSTALLATION WILL

CONFORM TO NYC CODE 608.13.2 TABLE 608.1 AND PC 312.10.2. A0507/8CH,A0523/8CH

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/27/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.