NYC Buildings

LAA Permit Department of Buildings

Permit Number: *240238710-LAA*

Issued: *09/28/2018 1:51 PM*

Expires: *09/28/2019*

Issued to: THEODORE J PUNSKOVSKY

Address: *BRONX 2776 JEROME AVENUE*

Business: JADA PLUMBING & HTG LLC

Floors: CEL

Licensee No: P - 002149

Description of Work: *Plumbing: WATER PLUMBING WORK*

INSTALL (1) 4" WILKINS 375 RPZ IN CELLAR. CONNECT TO EXISTING SERVICE. DEP APPROVAL #18075006. RUN APPROX 30' OF 4" NO HUB & CONNECT TO EXISTING WASTE STACK. THE INSTALLATION WILL CONFORM TO SECTIONS PC 608.13.2, PC TABLE 608.1 AND PC 312.10.2

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/11/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.

OP-35A (2/05)