



Buildings



LAA Permit Department of Buildings

Permit Number: 302104167-LAA

Issued: 03/16/2007
12:21 PM

Expires: 03/16/2008

Address: BROOKLYN 25 HANOVER PLACE

Issued to: IVAN TURKALJ

Business: KORDUN CONSTRUCTION CORP

Floors: 001

Licensee No: F - 000783

Description of Work: Fire Suppression: ADD/REPLACE/REPAIR/REARRANGE SPRINKLER HEADS/PIPING

REARRANGE MODIFY 20 EXISTING SPRINKLER HEADS ON EXISTING SPRINKLER SYSTEM. EXISTING OFFICE SPACE. SPRINKLER HEADS SHALL BE PENDANT TYPE ADJUSTABLE CONCEALED SPRINKLER HEADS. RELIABLE MODEL GI. 100 FT OF 1" PIPING

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/23/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.