



Buildings



LAA Permit Department of Buildings

Permit Number: 310287114-LAA

Issued: 04/27/2009
12:53 PM

Expires: 04/27/2010

Address: BROOKLYN 265 91 STREET

Issued to: MICHAEL DE MAIO

Floors: BAS

Business: D & D PLUMBING INC

Licensee No: P - 000927

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Heat, Water Heater

1968-OIL TO GAS CONVERSION. REPLACE EX'G BOILER WITH A PEERLESS & REPLACE EX'GHW WITH AN AO SMITH PGC100 HEATER 100,000BTU MEA#51-01-E & APPROX 70'X 1 1/4"GAS LINE. GAS TEST & CERT REQ. EX'G CHIMNEY.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 06/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.