



**Buildings**

# LAA Permit Department of Buildings

Permit Number: 310347835-LAA

Issued: 04/09/2010  
12:46 PM

Expires: 04/09/2011

Address: BROOKLYN 305 EIGHTH AVENUE

Issued to: STANLEY LEWIS

Floors: BAS

Business: STANLEY LEWIS CONTRG CORP

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 000247

Gas Usage(s): Heat

REPLACE (1) HB SMITH MDL#28HE-S-7 MEA#273-89-E VOL 2 GAS FIRED STEAM BOILER 2,088,000BTU & A POWERFLAME BURNER MDL#J5815 MEA#98-78E & CONNECT TO EX'G GASLINE & METER TYING INTO EX'G CHIMNEY. NO GAS TEST REQ. PW1 PLANS & APPLICATION TO FOLLOW. BTU'S ARE: 2,088,000 INPUT & 1,722,000 OUTPUT.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.