



Buildings



LAA Permit Department of Buildings

Permit Number: 310429872-LAA

Issued: 07/19/2011
10:46 AM

Expires: 07/19/2012

Address: BROOKLYN 7401 SHORE ROAD

Issued to: MICHAEL F SANTORO

Floors: CEL

Business: BORO FUEL OIL CO INC

Licensee No: 0 - 004219

Description of Work: oil: OIL TANK

CHANGE OF FUEL GRADE FROM #6 OIL TO #2 OIL. REMOVE SIDE ARM PRE-HEATER & INSTALL ANTI-SIPHON & HAND VALVE AT TANK. NO FIRING RATE CHANGE TO EXISTING FEDERAL FST-175 BOILER 5858MBTU MD#43491. DEP APPLICATION#CA140891Y.

Emergency Telephone Day or Night: 311

Borough Commissioner: 

Commissioner of Buildings: 

This permit copy created on 05/24/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.