



Buildings



LAA Permit Department of Buildings

Permit Number: 320653752-LAA

Issued: 03/20/2015
11:38 AM

Expires: 03/20/2016

Address: BROOKLYN 1816 AVENUE L

Issued to: RICHARD S RUDERMAN

Floors: CEL

Business: A. HTG AND PLBG WORKS INC

Licensee No: P - 000678

Description of Work: *Plumbing: WATER PLUMBING WORK*

*RENEWING AND IN CONJUNCTION WITH LAA#340082092. IN THE CELLAR INSTALL ONE 2" WATTS DCVA MODEL 007M1QT BACKFLOW PREVENTION DEVICE MEA#171-88-M IN VERTICAL FLOW-UP POSITION ON EXIST 2" COMBINED DOMESTIC & FIRE SPRINKLER WATER SERVICE. CONNECT 2" TO EXISTING BUILDING WATER SYSTEM. BACKFLOW DEVICE TESTER SHALL DISCHARGE WATER DURING DCVA TESTING AND MAINTENANCE AND DRAIN INTO EXISTING 4" GRAVITY WASTE STACK WITH CLEAN-OUT TO CITY GRAVITY SANITARY SEWER. DEP APPROVAL #13042338.
0122EF*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.