



**Buildings**

# LAA Permit Department of Buildings

Permit Number: 320670699-LAA

Issued: 07/24/2013  
4:44 PM

Expires: 07/24/2014

Address: BROOKLYN 106 UNION STREET

Issued to: FRANK C BERNIE

Floors: CEL

Business: KINGS PLAZA P & H INC

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 000514

Gas Usage(s): Heat

THIS APPLICATION IS BEING FILED FOR INSPECTION AND SIGN-OFF PURPOSES ONLY IN CONJUNCTION  
WITH LAA#310384802-DIRECT REPLACEMENT OF BURNHAM GAS FIRED  
STEAM BOILER-KIN 7 - 210,000 BTU'S MEA#154-93E. VENTED THROUGH EXISTING CHIMNEY - CHIMNEY  
IN GOOD CONDITION.

0702MAIL/0716MAIL

---

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.