



Buildings



LAA Permit Department of Buildings

Permit Number: 320793744-LAA

Issued: 08/24/2016
2:51 PM

Expires: 08/24/2017

Address: BROOKLYN 6817 3 AVENUE

Issued to: ROMICK K ADAMS

Floors: BAS 001 thru 004

Business: RKA PIPING AND HEATING

Licensee No: P - 002193

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Cooking

UPGRADING METER BARS AND MANIFOLD PIPING IN BAS, 8 CLASS 250 METER BARS FOR COOKING ON 1,2,3,4 FLS, REPLACING 560 FT TOTAL LENGTH OF 3/4 BLACK STEEL PIPE FROM BAS TO APT 4R&4L ON 4TH FL, APT 3L&3R ON 3RD FL, APT 2L&2R ON SECOND FL & APT 1L&1R ON 1ST FL. NO PIPES WILL RUN IN PUBLIC AREAS AND NO FIRESTOPPING WILL BE COMPROMISED. GAS IS FOR COOKING ONLY. ALL GAS METERS ARE IN BAS AND GAS STOVES ARE EXISTING IN APARTMENTS.

0823/6DM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/26/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.