



Buildings



LAA Permit Department of Buildings

Permit Number: 321341099-LAA

Issued: 10/03/2017
2:21 PM

Expires: 10/03/2018

Address: BROOKLYN 600 ATLANTIC AVENUE

Issued to: DANIEL G MISA

Business: DGM INDUSTRIES INC

Floors: 001

Licensee No: F - 000930

Description of Work: Fire Suppression: FIRE SUPPRESSION WORK

INSTALL (2) SPRINKLER HEADS ON THE 1ST FLOOR AND RUN APPROX 15' OF 1" SPRINKLER PIPING.
CONNECT TO EXISTING SERVICE. SYSTEM WILL BE SHUTDOWN APPROX 6 HOURS. SUPERSEDING
#340537609.REARRANGEMENT OF SPRINKLER HEADS DOES NOT HAVE TO BE DONE.
0907/7AP

Emergency Telephone Day or Night: 311

Borough Commissioner: 

Commissioner of Buildings: 

This permit copy created on 05/18/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.