



Buildings



LAA Permit Department of Buildings

Permit Number: **340022601-LAA**

Issued: **10/18/2012**
1:52 PM

Expires: **10/18/2013**

Address: **BROOKLYN 2 PIERREPONT STREET**

Issued to: **GUS ALATSIS**

Floors: **BAS**

Business: **JOHN'S PLBG & HTG, INC**

Licensee No: **P - 002021**

Description of Work: **Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)**

REMOVE SECTION OF 3" COMBINED SERVICE PIPE AND INSTALL NEW 3" RPZ WILKINS 375, MEA #49-01-M. RUN 4" AIR GAP LINE TO EXISTING DRAIN LINE. NYC DEP APPROVAL # 12039592

Emergency Telephone Day or Night: **311**

Borough Commissioner:

A handwritten signature in black ink, likely belonging to the Borough Commissioner.

Commissioner of Buildings:

A handwritten signature in black ink, which appears to read "James S. Oddo".

This permit copy created on 11/26/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.