



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 340040734-LAA

Issued: 02/18/2013  
12:41 PM

Expires: 02/18/2014

Address: BROOKLYN 1305 EAST 18 STREET

Issued to: CONSTANTINE D'ARCO

Floors: BAS

Business: S.J. FUEL CO., INC

Licensee No: 0 - 002414

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

DISCONNECTING SIDE ARM OIL HEATER,INSTALLING ANTI SIPHON VALVE ON OIL SUCTION LINE ,WIRE OIL PUMP TO RUN ONLY WHEN BURNER IS IN OPERATION. CHANGING GRADE OF OIL FROM #6 TO # 4 OIL . FIRING RATE TO REMAIN THE SAME. DEP. INSTALLATION #CA559385Y

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 02/22/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.