



Buildings



LAA Permit Department of Buildings

Permit Number: 340177739-LAA

Issued: 08/20/2014
8:26 AM

Expires: 08/20/2015

Address: BROOKLYN 65 BOND STREET

Issued to: JOHN L ZEPPELELLA

Floors: CEL

Business: ALL ABOUT P & H OF NY INC

Licensee No: P - 002122

Description of Work: Plumbing: OIL TO GAS CONVERSION

Gas Usage(s): Heat, Water Heater

REPLACE OIL BOILER WITH (1) GAS BOILER AND (1) HOT WATER HEATER. CONNECT TO EXISTING CHIMNEY. INSTALL METER BAR AND REPLACE 3/4" GAS LINE WITH APPROX 40' OF 1 1/4" GAS PIPING. (1) BURNHAM SING MEA#154-93-E 175,000 BTUS/INPUT 144,000 BTUS/OUTPUT (1) A/O SMITH XCV50 MEA#376-04-E 40,000 BTUS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.