




Buildings



LAA Permit Department of Buildings

Permit Number: 340202195-LAA

Issued: 10/30/2014
4:04 PM

Expires: 10/30/2015

Address: BROOKLYN 430 78 ST

Issued to: MICHAEL F SANTORO

Floors: CEL

Business: APPROVED OIL OF BKLYN, INC

Licensee No: 0 - 004219

Description of Work: oil: OIL BURNER/BOILER

OIL TO DUAL FUEL CONVERSION. REMOVE EXISTING OIL BURNER. INSTALL NEW POWER FLAME C2-GO-15 OIL AND GAS FIRED BURNER (CSI # 112250) CONNECTED TO EXISTING HB SMITH 28A-6 (CSA # 102104) 1,827,000 BTU INPUT AND 1,433,000 BTU OUTPUT. VENTED TO EXISTING CHIMNEY.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/26/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.