




Buildings



LAA Permit Department of Buildings

Permit Number: 340208732-LAA

Issued: 11/19/2014
3:26 PM

Expires: 11/19/2015

Address: BROOKLYN 430 78 STREET

Issued to: IRA AUSLANDER

Floors: CEL

Business: ARCO PLBG AND HTG INC

Licensee No: P - 001020

Description of Work: *Plumbing: GAS EQUIPMENT/PIPING*

Gas Usage(s): Heat, Other

ACTIVATE GAS PORTION OF EXIST MFG: POWERFLAME MDL #C2-GO-15 GAS/OIL BURNER; CSA #112250; FILED BY BURNER INSTALLER LIC #4219B; APL #340202195. CONNECT TO EXIST. MFG: HB SMITH MDL #28A-6 BOILER CSA #102104. 1,827,000 BTU INPUT; 1,433,000 BTU OUTPUT. INSTALL APPROX. 65 LF 3" BLACK PIPE CONNECT TO NEW GAS METER & METER BAR. VENT THROUGH EXIST. CHIMNEY

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/26/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.