



Buildings



LAA Permit Department of Buildings

Permit Number: 340235338-LAA

Issued: 03/03/2015
2:24 PM

Expires: 03/03/2016

Address: BROOKLYN 7402 RIDGE BOULEVARD

Issued to: JOHN M SANTULLI

Business: AGGRESSIVE HEATING INC

Floors: CEL

Licensee No: 0 - 005270

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

NOTIFICATION OF FUEL GRADE CHANGE FROM #6 OIL TO 2 OIL. WE WILL REMOVE THE WATER AND ELECTRIC OIL HEATERS AND INSTALL AN OIL ANTI SYPHON VALVE ON THE OIL SUPPLY LINE TO THE EXISTING FUEL BURNING EQUIPMENT. BOILER MAKE MODEL: BEST 5C - 150 (NEW) / BURNER MAKE MODEL: ICI DEG-63 (P) NEW

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/29/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.