



Buildings



LAA Permit Department of Buildings

Permit Number: 340265199-LAA

Issued: 05/28/2015
7:06 AM

Expires: 05/28/2016

Address: BROOKLYN 411 STATE STREET

Issued to: FRANK C BERNIE

Floors: CEL

Business: KINGS PLAZA P & H INC

Licensee No: P - 000514

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat

REPLACING EXISTING OIL FIRED BOILER WITH NEW GAS FIRED BOILER CONNECTING TO 60 FEET OF 1 1/2 INCH GAS PIPING FROM GAS METER TO NEW GAS BURNER. VENTING THROUGH EXISTING CLAY LINED CHIMNEY. NEW BOILER G19HE-04 WITH BECKETT CG-10 GAS BURNER. BTU'S 520,000

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.