



Buildings



LAA Permit Department of Buildings

Permit Number: 340311638-LAA

Issued: 10/06/2015
2:46 PM

Expires: 10/06/2016

Address: BROOKLYN 580 MAPLE ST

Issued to: MARK S SHELL

Floors: CEL

Business: M & M PIPING AND HEATING

Licensee No: P - 002368

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Heat, Water Heater

**OIL TO GAS CONVERSION* VENTED THRU EXISTING RED CLAY LINED CHIMNEY IN GOOD CONDITION. WILL INSTALL 1 WILLIAMSON BOILER MODEL GSA-300 BTU'S 300,000CSA#1502-81/262643 USING ABT 40 FT OF 1AND 1/2" BLACK PIPE. REGISTER 1 AO SMITH HWH MOD# PCG 75 BTUS 75,100 CSA#6917-01/ #037100_0_00 USING 20 FT OF 3/4 BLK PIPE. TEST GAS CELLAR REQUEST BLUE CARD. NO GAS PIPING IN PUBLIC HALLWAYS. FIRESTOP AS PER NYC CODE*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.