



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 340366703-LAA

Issued: 03/28/2016  
9:33 AM

Expires: 03/28/2017

Address: BROOKLYN 1315 50TH STREET

Issued to: ROBERT BAUER

Floors: CEL

Business: G. BAUER, INC

Licensee No: 0 - 005352

Description of Work: oil: OIL WORK

INSTALL ONE REPLACEMENT OIL BURNER WITH A DUAL FUEL OIL BURNER, WEBSTER, MODEL JB1C-07, UL# MP-2221 BOILER IS EXISTING FILLED UNDER JOB# 300171800 (FEDERAL, MODEL FST-50, INPUT 2,100,000 BTU'S, OUTPUT 1,674,000 BTU'S, UL# MH-16064) TO REMAIN; CONNECTED TO THE EXISTING METAL LINED CHIMNEY IN GOOD CONITION.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/17/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.