



Buildings



LAA Permit Department of Buildings

Permit Number: **340385461-LAA**

Issued: **05/24/2016
4:33 PM**

Expires: **05/24/2017**

Address: **BROOKLYN 768 48 STREET**

Issued to: **HENRY W TRAKTMAN**

Floors: **CEL**

Business: **METROPOLITAN HEAT & POWER**

Licensee No: **P - 001341**

Description of Work: **Plumbing: GAS PLUMBING WORK**

Gas Usage(s): Heat, Cooking, Water Heater

REPLACE OIL BOILER WITH GAS BOILER & HWH CONNECTED TO EXISTING TERRACOTTA LINED AND IN GOOD CONDITION CHIMNEY IN CELLAR AND CONNECTED TO APPROX 50' OF 1"-1/2" GAS PIPING. RECONNECT EXISTING 1ST FL COOKING LINE (APPROX 15' 3/4") TO EXISTING GAS METER AND TEST THE SAME. ONE BURNHAM MODEL#205NI-G2, INPUT 130MBH OUTPUT 108MBH. ONE AO SMITH HWH MODEL# XCV50 40,000 BTU/HR. FIRE STOPS FOR OUR WORK WILL BE RESTORED TO COMPLY WITH NYC CODE. NO GAS PIPE IN PUBLIC HALLWAYS. INSTALL NEW GAS METER BAR AND REMOUNT EXISTING METER TO NEW METER BAR 0602/6HT

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.