



Buildings



LAA Permit Department of Buildings

Permit Number: 340431296-LAA

Issued: 10/07/2016
1:56 PM

Expires: 10/07/2017

Address: BROOKLYN 536 48 ST

Issued to: GAETANO TABBANELLA

Floors: CEL 001 thru 002

Business: GT PLBG & HTG INC

Licensee No: P - 001522

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Cooking, Water Heater

REGISTER REPLACEMENT IN CELLAR GAS TO GAS BOILER WILLIAMSON, CSA#1502-81 MODEL:GWA240H245-N-5 BTU 245,000 AND AO SMITH, CSA#2901-05, MODEL:PGC75 BTU 75,000 VENTED THRU EXISTING CHIMNEY IN GOOD CONDITION. TEST 1ST AND 2ND FLOORS FOR COOKING. BLUE CARD REQUESTED. APPLIANCES ON EXISTING METER 1 ARE BOILER, HWH, STOVE. APPLIANCE ON EXISTING METER 2 IS STOVE. NO GAS PIPING IN PUBLIC HALLWAYS. FIRESTOP AS PER NYC CODE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.