



Buildings



LAA Permit Department of Buildings

Permit Number: **340624168-LAA**

Issued: **08/06/2018**
10:48 AM

Expires: **08/06/2019**

Address: **BROOKLYN 1305 EAST 18 STREET**

Issued to: **BERNARD BAUER**

Floors: **CEL**

Business: **G. BAUER, INC**

Licensee No: **0 - 005353**

Description of Work: **Oil: OIL WORK - FUEL GRADE CHANGE**

CHANGE FUEL GRADE FROM #4 TO #2. THE JOB HAS NO PRE-HEATER TO BE REMOVED SINCE IT'S RUNNING ON #4 OIL, ANTI-SIPHON VALVE IS EXISTING. CONNECT TO EXISTING GAS/OIL BURNER: ICI MEG-34P, BOILER: FEDERAL FST-80 FILED UNDER APPLICATION #F0 1190/85 DEP INSTALLATION #CA559385.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

A handwritten signature in black ink, likely of the Borough Commissioner.

Commissioner of Buildings:

A handwritten signature in black ink, likely of the Commissioner of Buildings.

This permit copy created on 02/24/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.