



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 340624168-LAA

Issued: 08/06/2018  
10:48 AM

Expires: 08/06/2019

Address: BROOKLYN 1305 EAST 18 STREET

Issued to: BERNARD BAUER

Floors: CEL

Business: G. BAUER, INC

Licensee No: 0 - 005353

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE FUEL GRADE FROM #4 TO #2. THE JOB HAS NO PRE-HEATER TO BE REMOVED SINCE IT'S RUNNING ON #4 OIL, ANTI-SIPHON VALVE IS EXISTING. CONNECT TO EXISTING GAS/OIL BURNER: ICI MEG-34P, BOILER: FEDERAL FST-80 FILED UNDER APPLICATION #F0 1190/85 DEP INSTALLATION #CA559385.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 02/22/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.