



Buildings



LAA Permit Department of Buildings

Permit Number: 340631212-LAA

Issued: 09/07/2018
1:08 PM

Expires: 09/07/2019

Address: BROOKLYN 235 ECKFORD STREET

Issued to: DOMINIC AIELLO

Floors: 001

Business: DOWNTOWN PLBG & HTG INC

Licensee No: P - 002298

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Cooking

DUE TO LEAK & GAS SHUTDOWN IN APT #1R ON THE 1ST FLOOR REPLACE METER BAR FOR EXISTING METER & REPLACE APPROX 10' OF 3/4" GAS PIPE & REPLACE GAS VALVE BEHIND STOVE. FOR COOKING ONLY. FIRESTOPS WILL NOT BE COMPROMISED. _RELOCATE METER WITHIN APT & RUN APPROX 6' OF 3/4" GAS PIPE.

A1108/8AP/JF

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.