



Buildings



LAA Permit Department of Buildings

Permit Number: 410260346-LAA

Issued: 09/09/2009
1:26 PM

Expires: 09/09/2010

Address: QUEENS 84-05 78 AVENUE

Issued to: VITO SALAMONE

Floors: BAS

Business: VINCESKI MAY PLB & HTG LL

Licensee No: P - 001505

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Heat

REPLACE 2 BOILER & 2 OIL BURNERS W/2 GAS BOILER & 2 GAS BURNERS. CONNECT TO EX'G CHIMNEY.
INSTALL NEW GAS SERVICE METER & PIPING. ALL WORK AT BSMT LEVEL. 2 POWERFLAME BURNERS
MEA#98-78E III MDL#JR30A-12. PW1 ALONG W/CORRESPONDING PW2 TO FOLLOW. ACTUAL BTU'S:
1,273,000 INPUT & 1,029,000 OUTPUT.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.