



Buildings



LAA Permit Department of Buildings

Permit Number: 420455019-LAA

Issued: 07/23/2013
4:41 PM

Expires: 07/23/2014

Address: QUEENS 41-25 49 STREET

Issued to: MICHAEL D SAVINO

Business: STATEWIDE OIL & HEATING

Floors: CEL

Licensee No: 0 - 005350

Description of Work: Oil: OIL BURNER/BOILER

REPLACE BOILER AND BURNER CONNECTED TO EXISTING CHIMNEY IN GOOD CONDITION. BOILER IS PEERLESS ECT6, INPUT = 420,000 BTU, MEA 182-94E. BURNER IS BECKETT #CF375, MEA 371-00E. THIS IS AN EMERGENCY REPLACEMENT WITH REFERENCE #8897.

0619MAIL/0715MAIL

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 10/27/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.