



Buildings



LAA Permit Department of Buildings

Permit Number: 421119220-LAA

Issued: 10/23/2015
11:54 AM

Expires: 10/23/2016

Address: QUEENS 140-11 ASH AVENUE

Issued to: LI KONG MA

Floors: CEL

Business: MPS PLUMBING & HEATING IN

Licensee No: P - 002039

Description of Work: Plumbing: WATER PLUMBING WORK

INSTALL (1) BACKFLOW PREVENTION DEVICES IN CELLAR. 4" WILKINS 375A (DOMESTIC 4" RPZ), MEA:484-04-E, CSA LISTING#6813-01, FILE#212814. ALL DISCHARGES CONNECT TO EXISTING DRAIN IN CELLAR. DEP APPROVED#12036245. ATTACHED DEP LETTER. EXISTING LAA #420451825 EXPIRED, SUPERSEDE IT. EXISTING ALL VIOLATIONS WITH THIS JOB IS NOT INVOLVED, ATTACHED L2.

917/5L(MPS)*/1016/5L(MPS)

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/13/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.