



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 421291854-LAA

Issued: 04/24/2017  
4:27 PM

Expires: 04/24/2018

Address: QUEENS 30-22 32 STREET

Issued to: NICHOLAS DAMOULAKIS

Floors: CEL 001 thru 004

Business: N & D PLBG & HTG CORP

Licensee No: P - 001570

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Cooking, Water Heater, Dryer

EWN#13344. CONED SHUT DOWN GAS SERVICE TO ENTIRE BUILDING DUE TO GAS LEAK. WE'LL TEST THE EX'G 9 GAS RISERS FROM CEL-4TH FL & MAKE REPAIRS IF NECESSARY (PAA TO BE FILED IF NECESSARY). GAS USAGE FOR 8 GAS METERS: COOKING FOR 8 APTS (2 APTS/FL FROM 1-4TH FL), 8 HWH & 8 BOILERS (1/APT). GAS USE FOR 9TH GAS METER: 1 HWH, 1 BOILER & 1 DRYER FOR COMMON SPACE. ALL BOILERS, HWH, & DRYER LOCATED IN CEL (FILED UNER 401596144) GAS TEST & GAS AUTH REQUIRED. NO GAS PIPING IN PUBLIC HALLWAY & NO FIRE STOPS WILL BE COMPROMISED. 0421/7AZ

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 12/28/2025 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.