



Buildings



LAA Permit Department of Buildings

Permit Number: 421509460-LAA

Issued: 03/30/2018
11:02 AM

Expires: 03/30/2019

Address: QUEENS 41-21 24 STREET

Issued to: FRANK SBEGLIA

Floors: CEL

Business: COPPER SERVICES, LLC

Licensee No: P - 000789

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Dryer

CONED RED TAGGED(QG180000625 CALL TICKET),METER#3829666L LOCKED,DUE TO FIRE FROM TWO COMMERCIAL DRYERS.METER TO BE TAKEN DOWN AND TESTED TO MAKE SURE IT HOLDS 90PSI.EXISTING RISER IN CELLAR FROM GAS METER ROOM TO LAUNDRY ROOM, EXISTING CLASS 250 METER BAR IN METER ROOM.THERE IS APPX.30'-40' OF 11/4" BLACK PIPE LEADING TO THE TWO COMMERCIAL DRYERS.5' OF 1/2" BLACK TO BE USED TO CONNECT TWO DRYERS.GAS PIPE WIL BE TESTED AS PER DOB RULES AND REGULATIONS.
0222/8JC

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/11/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.