




Buildings



LAA Permit Department of Buildings

Permit Number: 440034446-LAA

Issued: 01/08/2013
3:20 PM

Expires: 01/08/2014

Address: QUEENS 41-12 41 STREET

Issued to: BERNARD BAUER

Floors: CEL

Business: G. BAUER, INC

Licensee No: 0 - 005353

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE FUEL GRADE FROM #6 TO #2. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SYPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CA227384L.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/25/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.