



Buildings



LAA Permit Department of Buildings

Permit Number: 440046040-LAA

Issued: 02/20/2013
3:43 PM

Expires: 02/20/2014

Address: QUEENS 1665 PALMETTO STREET

Issued to: DANIEL D VESSIO

Floors: CEL

Business: NULITE FUEL OIL CO LTD

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 001378

Gas Usage(s): Heat, Water Heater

GAS TO GAS BOILER REPLACEMENT. REPLACE GAS BOILER WITH A NEW WEIL MCLAIN BOILER MEA#159-75E MODLE EG75 ONE BOILER 300,000 BTU INPUT 240,000 BTU OUTPUT. REPLACE AO SMITH HOT WATER HEATER MEA#346-06 E BTU'S 75,000. MODLE PCG100-300. CONNECT BOILER TO EXISTING 11/4" GAS LINE AND VENT TO LINED CHIMNEY. NO GAS PRESSURE TEST NEEDED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/12/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.