



Buildings



LAA Permit Department of Buildings

Permit Number: 440051943-LAA

Issued: 03/05/2013
9:34 AM

Expires: 03/05/2014

Address: QUEENS 319 BEACH 98 STREET

Issued to: VITO VAVALLO

Floors: BAS

Business: H2O PLUMBING INC

Licensee No: P - 002116

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Heat, Boiler Pilot

INSTALL ONE NEW REPLACEMENT GAS BURNER RIELLO MODEL RS500 USING 16,000 CFH OF GAS ETL#3182696 ON EXISTING FEDERAL PLW-397 MD#58357-01 CB#204500Z. CONNECT TO EXISTING GAS PIPING. EXISTING BURNER HAS BEEN DAMAGED BEYOND REPAIR BY HURRICANE SANDY.PW-1 WITH FULL FILING TO FOLLOW IN 60 DAYS.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 04/11/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.