




Buildings



LAA Permit Department of Buildings

Permit Number: 440119621-LAA

Issued: 12/09/2013
4:58 PM

Expires: 12/09/2014

Address: QUEENS 142-20 FRANKLIN AVENUE

Issued to: GARY F JACCARINO

Business: SILVER STAR PLBG & HTG IN

Floors: CEL

Licensee No: P - 001315

Description of Work: Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)

FILE FOR (1) 4" WILKINS 375A RPZ/BFP IN CELLAR ON EXISTING DOMESTIC SERVICE.MEA #484-04-M. AND (1) 6" WILKINS 350DA RPZ/BFP MEA# 147-99-M, ON EXISTING SPRINKLER SERVICE, WITH (1) 3/4" BYPASS, WILKINS 950XL MEA #426-8-M. ALL LOCATED IN CELLAR AND DISCHARGED TO NEAREST DRAIN. DEP APPROVAL #11029284.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/13/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.