



Buildings



LAA Permit Department of Buildings

Permit Number: 440120085-LAA

Issued: 12/11/2013
11:35 AM

Expires: 12/11/2014

Address: QUEENS 35-34 84 STREET

Issued to: RICHARD BONELLI

Floors: CEL

Business: BONDEE ENTERPRISES INC

Licensee No: 0 - 005087

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

IN CELLAR FUEL GRADE CHANGE FROM #6 TO #4 OIL. PREHEATER TO BE DISCONNECTED IN PLACE.
ANTI SYPHON VALVE TO BE INSTALLED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/26/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.