



Buildings



LAA Permit Department of Buildings

Permit Number: 440313750-LAA

Issued: 05/25/2016
8:34 AM

Expires: 05/25/2017

Address: QUEENS 2115 BROADWAY

Issued to: DOMINGO E VALERA

Business: DOVAL PLBG & HTG CORP

Floors: CEL

Licensee No: P - 001316

Description of Work: Plumbing: WATER PLUMBING WORK

INSTALLATION OF NEW 1 1/2" RPZ WILKINS 975 XL2 LEAD FREE NYC MEA 425-89-M VOL 3 ON THE MAIN DOMESTIC WATER SERVICE FOR SUPERMARKET DRAINING INTO EXISTING FLOOR DRAIN. REPLACEMENT OF WILKINS 6" 350 DA DCDA WITH 3/4" BY PASS METER NYC MEA 147-99-M VOL 4 FOR FIRE SERVICE. DRAINING INTO EXISTING FLOOR DRAIN. DEP APPROVAL 15059279.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 09/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.