



Buildings



LAA Permit Department of Buildings

Permit Number: 440318611-LAA

Issued: 06/17/2016
11:25 AM

Expires: 06/17/2017

Address: QUEENS 44-41 PURVES STREET

Issued to: BRAD F SCHMELZER

Floors: 001,002

Business: BRADFORD MECH. CONTR INC

Licensee No: P - 001194

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): HVAC, Other

PERFORM GAS TEST ON AN EXISTING 3" GAS LINE APPROX. 50' IN LENGTH SERVING AN EMERGENCY GAS GENERATOR THAT IS LOCATED ON THE SECOND FLOOR IT IS THE ONLY GAS APPLIANCE CONNECTED TO THIS GAS LINE AND GAS METER. PLEASE NOTE THE FOLLOWING INFORMATION: IT WAS DETERMINED BY CON EDISON THAT THERE WAS A GAS LEAK LOCATED IN THE EXISTING GAS METER ROOM AND THE GAS METER AND REGULATOR TO THIS GAS GENERATOR LINE WAS SHUT OFF. UPON OUR INSPECTION WE REPLACED A DEFECTIVE 2" ELBOW.

A0629/6ES/A0728/6ES

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.