



Buildings

LAA Permit Department of Buildings

Permit Number: 440351799-LAA

Issued: 10/10/2016
12:53 PM

Expires: 10/10/2017

Address: QUEENS 4007 67 STREET

Issued to: EDWARD FITZSIMONS

Floors: CEL,001,002,003,004

Business: NEW AMSTERDAM PLBG & HTG

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 001484

Gas Usage(s): Cooking

GAS TO APT 45 SHUT DOWN BY NAT GRID DUE TO LEAK. FOUND LEAK ON 3/4 GAS APPLIANCE VALVE AND STOVE FLEX. REPLACED 3/4 INCH GAS BALL VALVE AND 3/4 INCH STOVE CONNECTOR FLEX. TESTED ENTIRE LINE WITH 3-LBS OF PRESSURE FROM METER IN CELLAR TO STOVE IN KITCHEN OF APT 45 ON THE 4TH FLOOR. LINE SUCCESSFULLY HELD TEST PRESSURE

1024/6EF

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/12/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.