



Buildings



LAA Permit Department of Buildings

Permit Number: 440378477-LAA

Issued: 01/18/2017
3:32 PM

Expires: 01/18/2018

Address: QUEENS 43-40 40 STREET

Issued to: HENRI J BILLHARZ

Floors: CEL 001 thru 004

Business: BILLHARZ PLUMBING, INC

Licensee No: P - 001986

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

REPLACE (4) GAS RISERS & LOCKWING GAS COCKS IN THE CELLAR FOR RISER LINES A, B, C, D. REPLACE APPROX 50' OF 1 1/4", 80' OF 1" & 80' OF 3/4" GAS PIPING FROM THE CELLAR TO THE (16) EXISTING RESIDENTIAL STOVES IN APTS 1A-4A, 1B-4B, 1C-4C & 1D-4D (FLS 1-4). REPLACE GAS VALVES & FLEX CONNECTORS BEHIND EACH STOVE. FIRESTOPS WILL NOT BE COMPROMISED. PIPING WILL BE THRU APTS & NOT IN HALLWAYS. (METER IS EXISTING).

0214/7AP/JF

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/26/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.