



Buildings



LAA Permit Department of Buildings

Permit Number: 440386850-LAA

Issued: 02/23/2017
4:01 PM

Expires: 02/23/2018

Address: QUEENS 119-40 UNION TURNPIKE

Issued to: VITO VAVALLO

Floors: CEL

Business: H2O PLUMBING INC

Licensee No: P - 002116

Description of Work: Plumbing: WATER PLUMBING WORK

INSTALL ONE NEW PRIMARY BACK FLOW PREVENTION DEVICE A 4" WATTS MODEL 957 RPZ OS&Y DEVICE
UL#EX3185 WITH A 4" AIR GAP W/FUNNEL CONNECTED TO A 3" DRAIN LINE CONNECTED TO EXISTING
4" WAIST RISER CONNECTED BY GRAVITY TO EXISTING HOUSE SEWAR PIPING IN ACCORDANCE WITH NYC
BUILDING CODE. DEC APPROVAL 17066035

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 10/27/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.