



Buildings

LAA Permit Department of Buildings

Permit Number: 440433452-LAA

Issued: 09/11/2017
3:07 PM

Expires: 09/11/2018

Address: QUEENS 45-45 40 ST

Issued to: PERRY NATHANAIL

Floors: CEL

Business: OLYMPIAN FUEL OIL CORP

Description of Work: oil: OIL WORK

Licensee No: O - 004262

REPLACE EXISTING OIL FIRED BOILER WITH NEW OIL FIRED BOILER. PEERLESS MODEL #ECT-5 WITH 350,000 BTU INPUT AND 286,000 OUTPUT. NEW BECKETT MODEL #AFG OIL BURNER. CONNECT TO EXISTING CHIMNEY WHICH IS IN GOOD CONDITION

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/12/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.