



Buildings



LAA Permit Department of Buildings

Permit Number: 440477164-LAA

Issued: 04/17/2018
4:12 PM

Expires: 04/17/2019

Address: QUEENS 41-12 41 STREET

Issued to: ALAN I BOMZER

Floors: CEL 001 thru 005

Business: G.B. & SON, INC

Licensee No: P - 000964

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

DUE TO A GAS SHUTDOWN BY THE UTILITY COMPANY, WE WILL TEST GAS LINE FROM METER IN CELLAR UP TO THE 5TH FL APT 5H. WILL REPLACE APPROX 100' OF 3/4" GAS PIPING CONNECTED TO APT & 3/4" VALVE & FLEX CONNECTOR BEHIND THE STOVE. ALSO INSTALL 1" LOCKWING GAS COCK & 1" METER BAR. THERE WILL BE NO GAS PIPING IN ANY PUBLIC HALLWAYS. FIRESTOPS WILL BE RESTORED AS PER NYC CODE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/25/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.