



LAA Permit Department of Buildings

Permit Number: 440507505-LAA

Issued: 09/06/2018
1:06 PM

Expires: 09/06/2019

Address: QUEENS 1675 CORNELIA STREET

Issued to: MANUEL ARANDA

Floors: CEL

Business: ARANDA PLBG & HTG CORP

Licensee No: P - 001969

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Water Heater

OIL TO GAS CONVERSION. REPLACE OIL BOILER WITH 1 GAS BOILER & 1 GAS HW HEATER AT CELLAR, BOTH TO BE VENTED THRU THE EXISTING CHIMNEY W/ TC LINER IN GOOD CONDITION. INSTALL NEW METER BAR AND INSTALL APPROX. 60FT OF 2" & 20 FT OF 3/4" GAS PIPING TO BOILER ROOM & PERFORM TEST OF THE SAME. GAS CARD IS REQUIRED. NO PIPING IN PUBLIC AREAS. FIRESTOPS WILL NOT BE DISTURBED.

_A0412/9SC

Emergency Telephone Day or Night: 311

Borough Commissioner:

A handwritten signature in black ink, reading "Tina Meisel".

Commissioner of Buildings:

A handwritten signature in black ink, reading "James S. Oddo".

This permit copy created on 11/30/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.