



Buildings



LAA Permit Department of Buildings

Permit Number: 54000611-LAA

Issued: 11/10/2011
9:23 AM

Expires: 11/10/2012

Address: STATEN ISLAND6 SCRIBNER AVE

Issued to: JOSEPH E FERDINANDO

Floors: BAS

Business: RICHMOND P&H CO INC

Licensee No: P - 000659

Description of Work: Plumbing: OIL TO GAS CONVERSION

Gas Usage(s): Heat

REPLACE 1 OIL BOILER WITH 1 BURNHAM GAS BOILER IN BASEMENT. MEA#154-93-EV3. MODEL# KIN5LNI-LE2.INPUT BTUS 175,000 AND OUTPUT BTUS 144,000. CONNECT TO EXISTING CHIMNEY, RUN APPROXIMATLY 30FT OF 1" GAS PIPE. CONNECT TO EXISTING GAS PIPING AND METER.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/11/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.